


## TEST CERTIFICATE

### SUMMARY OF TEST RESULTS

<b>NUMBER</b>	<b>0440</b>	<b>DATE</b>	<b>28 /06 / 04</b>
---------------	-------------	-------------	--------------------

<b>Client' s data:</b>	<b>ALUSET - DIELASI</b> THESI SKALISTIRI GR 193 00 ASPROPYRGOS ATTIKIS GREECE
<b>Product description:</b>	<b>SINGLE SASH WINDOW OPENING / TILTING</b>
<b>Material:</b>	<b>ALUMINIUM</b>
<b>System :</b>	<b>ALUSET C - 520</b>



1215 x 955 mm

<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 4</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class 9A</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class C4</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOI PAPAPOU LOU**  
TECHNICAL MANAGER



**IOANNIS GKERTSOS**  
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL