


TEST CERTIFICATE

SUMMARY OF TEST RESULTS

NUMBER	0448	DATE	08 /07 / 04
---------------	-------------	-------------	--------------------

Client' s data:	ALUSET - DIELASI THESI SKALISTIRI GR 193 00 ASPROPYRGOS ATTIKIS GREECE
Product description:	SINGLE SASH WINDOW THERMOBREAK OPENING / TILTING
Material:	ALUMINIUM
System :	ALUSET T - 530



1205 x 945 mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 3
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class E900
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C3

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOI PAPAPOU LOU
TECHNICAL MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL